EVAPCO, INC. UNIT MODEL # DWG. # SERIAL # **CLOSED CIRCUIT COOLER** NTS W2091212-MRC-RS 5/10/2024 eco-ATC-1002A NOTES: 1. (M)- FAN MOTOR LOCATION (M)**BOTTOM OUTLET** 2. HEAVIEST SECTION IS UPPER SECTION 3. MPT DENOTES MALE PIPE THREAD 460 1826 FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING 4. + UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE SEPARATE DRAWINGS FOR ACCESSORIES) 5. 19mm DIA. MOUNTING HOLES. REFER TO 2578 RECOMMENDED STEEL SUPPORT 6. THE SPRAY PUMP SHOULD BE SIZED FOR 35 L/S AND 17 kPa AT THE INLET CONNECTION 7. *- APPROXIMATE DIMENSIONS DO NOT USE FACE 2 FOR PRE-FABRICATION OF CONNECTING **PIPING** 3651 FACE 1 **PLAN VIEW** 502 ACCESS DOOR 35 - 670 – 1238 -0 2677 283 150 FPT -(2) 100 BFW FLUID IN **INLET** (2) 15 FPT VENTS 1067 4102 (2) 100 BFW FLUID OUT 130 1426 2578 3651 FACE 2 FACE 1 NO. OF SHIPPING SECTIONS SHIPPING OPERATING HEAVIEST SECTION 7125 9765 6300 2 kg kg WEIGHT WEIGHT WEIGHT