EVAPCO, INC. UNIT MODEL # DWG. # DATE SERIAL # **CLOSED CIRCUIT COOLER** ATC-1007E NTS W2090808-MRC-RS 5/7/2024 NOTES: 1. (M)- FAN MOTOR LOCATION 2. HEAVIEST SECTION IS UPPER SECTION **BOTTOM OUTLET** (M) 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD 460 BFW DENOTES BEVELED FOR WELDING 1289 4. + UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE SEPARATE DRAWINGS FOR ACCESSORIES) 5. 19mm DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT 2282 6. THE SPRAY PUMP SHOULD BE SIZED FOR 21 L/S AND 17 kPa AT THE INLET CONNECTION 7. *- APPROXIMATE DIMENSIONS DO NOT USE FOR PRE-FABRICATION OF CONNECTING FACE 2 **PIPING** 2578 FACE 1 **PLAN VIEW** 543 **ACCESS** DOOR - 1130 575 2181 283 100 FPT Ó-INLET (2)15 FPT VENT (2) 100 BFW FLUID IN 3404 686 (2) 100 BFW **FLUID OUT** 0-130 1222 2578 2283 FACE 2 FACE 1 NO. OF SHIPPING SECTIONS SHIPPING OPERATING HEAVIEST SECTION 3775 4985 3185 2 kg kg WEIGHT WEIGHT WEIGHT