

EVAPCO, INC.



UNIT	COOLING TOWER	MODEL #	SCALE	DWG. #	REV.	DATE	SERIAL #
			NTS	RP171448-MRB-SLF			

NOTES:

1. (M)- FAN MOTOR LOCATION
2. HEAVIEST SECTION IS LOWER SECTION
3. MPT DENOTES MALE PIPE THREAD
FPT DENOTES FEMALE PIPE THREAD
BFW DENOTES BEVELED FOR WELDING
4. + UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE SEPARATE DRAWINGS FOR ACCESSORIES)
5. 19mm DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING
6. MAKE-UP WATER PRESSURE-137 kPa MIN, 344 kPa MAX

FACE 1
PLAN VIEW


(2)200 BFW/
GROOVED INLET

(2) 50 MPT
MAKE-UP


(2) 80 MPT
DRAIN

(2)200 BFW/
GROOVED OUTLET


(2) 80 MPT
OVERFLOW



FACE 1



FACE 2



FACE 2

SHIPPING WEIGHT	6196	kg +	OPERATING WEIGHT	10061	kg	HEAVIEST SECTION WEIGHT	2108	kg	NO. OF SHIPPING SECTIONS	4
-----------------	------	------	------------------	-------	----	-------------------------	------	----	--------------------------	---